# Ventilation Guidelines for Flammable and Chemical Storage Cabinets — Quick Tips



Chemical storage cabinets, whether used for flammables, corrosives or pesticides/poisons, come with capped bung openings that allow for ventilation. While cabinet manufacturers may provide the bungs for ventilation purposes, venting flammable liquid storage cabinets is NOT required or even recommended by any federal regulatory agency. Cabinet manufacturers include venting bungs for users who may be required to vent by state or local codes, individual company policies, insurance carrier policies or any other authority having jurisdiction (AHJ).

## Don't Vent Unless You Have To

According to the National Fire Protection Association (NFPA) Code 30, Flammable and Combustible Liquids Code, venting a flammable storage cabinet is not necessary for fire protection purposes. Flammable and combustible liquid storage cabinets are designed to help protect the internal contents from a fire outside of the cabinet. A vented cabinet could compromise the ability of the cabinet to protect its contents from a fire.

NFPA 30-2018 Edition, 9.5.4 states, "Storage cabinets shall not be required by this code to be ventilated for fire protection purposes." Additionally, in Annex A, NFPA offers further reinforcement that venting is not necessary. A.9.5.4 states, "Venting storage cabinets has not been demonstrated to be necessary for fire protection purposes. Additionally, venting a cabinet could compromise the ability of the cabinet to adequately protect its contents from involvement in a fire because cabinets are not generally tested with venting. Therefore, venting of a storage cabinet is not recommended."

If venting is being considered, 9.5.4.2 addresses some minimal design requirements. It states, "If a storage cabinet is ventilated for any reason, the vent openings shall be ducted directly to a safe location outdoors or to a treatment device designed to control volatile organic compounds (VOCs) and ignitable vapors in such a manner that will not compromise the specified performance of the cabinet and in a manner that is acceptable to the AHJ." If the cabinet is not vented, the NFPA code requires that the bung caps remain sealed as 9.5.4.1 states, "If a storage cabinet is not ventilated, the vent openings shall be sealed with the bungs supplied with the cabinet or with bungs specified by the manufacturer."

While not federally mandated, state or local AHJ may require venting. NFPA 30 acknowledges this under A.9.5.4 where it states, "However, it is recognized that some jurisdictions might require storage cabinets to be vented and that venting can also

be desirable for other reasons, such as health and safety."

# How Do I Know If I Need to Vent My Flammable Storage Cabinet and How Is It Done?

As it's clearly indicated above, from a federal regulatory compliance perspective there is no requirement to vent a cabinet. To determine if additional regulations or requirements apply to your specific situation, you'll need to confer with your AHJ.


Should you learn from your AHJ that ventilating your flammable storage cabinet is a requirement, be sure to obtain clear and detailed instructions as to how the cabinet needs to be vented. They should not only supply the "how" but also specific requirements for the equipment needed to mechanically vent the cabinet.

NFPA 30 does offer additional venting guidance should the AJH deem it necessary. A.9.5.4.2 states "A "safe location" should be selected as the location of a vent discharge to minimize the potential for ignitable vapors to travel to a source of ignition after discharge from the vent. Electrical equipment that does not meet the requirements for hazardous locations can serve as an ignition source. The Technical Committee advises that vent discharge locations should consider such factors as the following:

- 1. Characteristics of the exhausted material (vapor density, toxicity, velocity of discharge, etc.)
- 2. Proximity to potential ignition sources
- 3. Building openings such as doors, windows, air intakes and so forth
- 4. Dispersion characteristics (distance to discharge within the flammable range, direction of discharge, atmospheric conditions, and the influence of building and neighborhood buildings on discharge vapors)
- 5. Likelihood of vapor accumulation following discharge, such as an accumulation under building eaves
- 6. Likelihood of sufficient discharge volume to allow an ignitable concentration to reach an ignition source

Historically, NFPA 30 has provided prescriptive guidance, often based on area classification requirements, and results have been acceptable. Closer distances should be accepted only if an analysis by a qualified person justifies closer distances. Similarly, the specified distances might not be acceptable for all installations, thus the guidance provided above.

Again, these are general guidelines taken from current NFPA references. Your AHJ that's requiring you to vent is the ultimate authority regarding how the cabinet must be vented.



The above NFPA guidelines refer specifically to flammable liquid storage cabinets; if, at the request of your AHJ, you're required to vent a corrosives/acid cabinet, make sure to incorporate a blower that's compatible with the vapors being exhausted. Also be aware that if it's a hazardous material you're venting, you may not be allowed to exhaust to the outside due to the health hazards the vapors present.

For more information on chemical storage in the workplace, see Quick Tips #181: Chemical Compatibility Concerns in Storage. For additional information on flammable liquids in the workplace, see Quick Tips #179: Flammable Liquids and Quick Tips #180: NFPA 30: A Guide to Flammable Liquids.

## **Commonly Asked Questions**

Q: Are there any options short of venting to control the levels of vapors inside flammable and chemical storage cabinets?

A: Vapor trap filters are available for storage cabinets that contain activated carbon to aid in lowering the levels of VOCs or corrosive vapors inside the cabinets.

# Q: Do I need self-closing doors?

A: Self-closing doors are not a federal requirement; however, some states and/or local municipalities do enforce the International Fire Code (IFC) or the NFPA 1 Fire Code which does mandate self-closing doors. To find out if you are in an area that requires self-closing doors, contact your local fire marshal or AHJ.

### Sources

NFPA 30 Flammable and Combustible Liquids Code, 2018 Edition 29 CFR 1910.106 Flammable Liquids

The information contained in this article is intended for general information purposes only and is based on information available as of the initial date of publication. No representation is made that the information or references are complete or remain current. This article is not a substitute for review of current applicable government regulations, industry standards, or other standards specific to your business and/or activities and should not be construed as legal advice or opinion. Readers with specific questions should refer to the applicable standards or consult with an attorney.

Source: Grainger Know How - https://www.grainger.com/know-how